



# Nineveh-Hensley-Jackson United School Corporation

802 S Indian Creek Drive | Trafalgar, IN 46181

P: 317.878.2100 | F: 317.878.2109

[www.indiancreekschools.com](http://www.indiancreekschools.com)

*Indian Creek Schools*

April 30, 2021

Dear Indian Creek High School Parents:

The Indian Creek High School recently participated in a voluntary State program to test our schools' drinking water for lead. This program was offered to all Indiana public schools and child care facilities, and it specifically tests water fixtures that provide drinking or cooking water to students.

In our Indian Creek High School, a total number of 103 fixtures were tested. 100% of those fixtures did not present lead levels that exceed the U.S. Environmental Protection Agency (EPA)'s "action level" of 15 parts per billion (ppb).

If you would like a copy of the complete testing results or more information about the findings, please contact our office at [jsneed@nhj.k12.in.us/317-878-2180](mailto:jsneed@nhj.k12.in.us/317-878-2180), Monday through Friday (7:30-3:30).

Sincerely,

Jared Sneed  
Director of Facilities